



2022 Annual Drinking Water Quality Report

Lake Suzy Subdivision, PWS #6144856



MAY 5, 2023

DESOTO COUNTY UTILITIES

2170 N.E. Roan Street

2022 Annual Drinking Water Quality Report

Lake Suzy Subdivision, PWS #6144856

The Peace River Manasota Regional Water Supply Authority (PRMRWSA) oversees the operations of the Peace River Manasota Regional Water Supply Facility (PRMRWSF), which uses the Peace River as its source of supply. The Peace River is a large river, by Florida standards, having a drainage area of 2,300 square miles. The Peace River headwaters originate in the Green Swamp of northern Polk County flowing through Lake Hancock, Winter Haven chain of lakes and Lake Hamilton. The mouth of the Peace River is located in Punta Gorda; 120 miles downstream from the headwaters delivering needed fresh water to the Charlotte Harbor estuary. The water is treated for drinking by coagulation, flocculation, sedimentation, filtration, and is disinfected by chloramination. The PRMRWSA presently sells water to Charlotte County, the City of North Port, DeSoto County, Manatee County and Sarasota County.

The PRMRWSA, DeSoto County Utilities, and Lake Suzy Subdivision routinely monitor for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2022. Data obtained before January 1, 2022, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations. We have learned that through our monitoring and testing that some constituents have been detected. If you have any questions about the data provided in this Annual Drinking Water Quality Report please contact the office at 863-491-7500.

In 2022, the Florida Department of Environmental Protection performed a Source Water Assessment for The Peace River Manasoto Regional Water Supply. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at <https://fldep.dep.state.fl.us/swapp/> .

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Locational Running Annual Average (LRAA): The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Millirem per year (mrem/yr): measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU): measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

"ND" means not detected and indicates that the substance was not found by laboratory analysis.

Parts per billion (ppb) or micrograms per liter ($\mu\text{g}/\text{l}$): one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Radioactive Contaminants – Peace River Authority

These contaminants are required to be tested on a monthly basis. Test results are for the period 1/1/2022 – 12/31/2022. These test results show no violations occurred during this period.

| Contaminant and Unit of Measurement | Dates of sampling (mo. /yr.) | MCL Violation Y/N | Level Detected | Range of Results | MCLG | MCL | Likely Source of Contamination |
|---|------------------------------|-------------------|----------------|------------------|------|-----|--------------------------------|
| Alpha emitters (pCi/L) | 1/22-12/22 | N | 2.1 | 1.5 – 2.1 | 0 | 15 | Erosion of natural deposits |
| Radium 226 + 228 or combined radium (pCi/L) | 1/22-12/22 | N | 0.9 | 0.3 – 0.9 | 0 | 5 | Erosion of natural deposits |

Turbidity Contaminants – Peace River Authority

The monitoring of turbidity occurs at least 6 times per day as required by the regulations. The data provided represents the turbidity from the combined filtered water location at Peace River Facility. Test results are for the period 1/1/2022 – 12/31/2022. The Peace River Facility combined filtered water turbidity never exceeded the MCL of 1.0 and meets on a monthly basis, the requirement of less than or equal to .30 level at least 95% of the time.

| Contaminant and Unit of Measurement | Dates of sampling (mo. /yr.) | MCL Violation Y/N | Highest Single Measurement | The Lowest Monthly Percentage of Samples Meeting Regulatory | MCLG | MCL | Likely Source of Contamination |
|-------------------------------------|------------------------------|-------------------|----------------------------|---|------|-----|--------------------------------|
| Turbidity (NTU) | 1/22 – 12/22 | N | .19 | 95% | N/A | TT | Soil runoff |

Stage 1 Disinfectant/Disinfection Byproduct (D/DBP) Parameters – Lake Suzy Subdivision

| Disinfectant or Contaminant and Unit of Measurement | Dates of sampling (m/yr.) | MCL or MRDL Violation Y/N | Level Detected | Range of Results | MCLG or MRDLG | MCL or MRDL | Likely Source of Contamination |
|---|---------------------------|---------------------------|----------------|------------------|---------------|-------------|---|
| Chloramines (ppm) | 1/22-12/22 | N | 3.4 | 1.8-3.4 | 4 | 4 | Water additive used to control microbes |

Stage 2 Disinfectant/Disinfection Byproduct (D/DBP) Parameters – Lake Suzy Subdivision

| Disinfectant or Contaminant and Unit of Measurement | Dates of sampling (M/yr.) | MCL or MRDL Violation Y/N | Level Detected | Range of Results | MCLG or MRDLG | MCL or MRDL | Likely Source of Contamination |
|---|---------------------------|---------------------------|----------------|------------------|---------------|-------------|---|
| Haloacetic Acids (five) (HAA5) (ppb) | 1/22-12-22 | N | 22.5 | 14.0-28.0 | N/A | 60 | By-product of drinking water disinfection |
| TTHM (total trihalomethanes) (ppb) | 1/22-12/22 | N | 33.5 | 23.0-43.0 | N/A | 80 | By-product of drinking water disinfection |

Lead and Copper (Tap Water) – Lake Suzy Subdivision

These contaminants are required to be tested annually every three years. Test results are for the period 1/1/2021 -12/31/2021, These results are from the most recent testing done in accordance with State and Federal regulations, No violations occurred during this period and 100% of the samples for both lead and copper were below the action level.

| Contaminant and Unit of Measurement | Dates of sampling (m/yr.) | AL Exceedance Y/N | 90th Percentile Result | No. of sampling sites exceeding the AL | MCLG | AL (Action Level) | Likely Source of Contamination |
|-------------------------------------|---------------------------|-------------------|------------------------|--|------|-------------------|---|
| Copper (tap water) (ppm) | 6/21 | N | 0.034 | 0 | 1.3 | 1.3 | Corrosion of household plumbing systems; erosion of natural deposits; |
| Lead (tap water) (ppb) | 6/21 | N | 2.3 | 0 | 0 | 15 | Corrosion of household plumbing systems; erosion of natural deposits |

Microbiological Contaminants

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | TT Violation | Result | MCLG | TT | Likely Source of Contamination |
|-------------------------------------|---------------------------|--------------|----------|------|----|--------------------------------------|
| Total Coliform Bacteria* | 1/1/2022 – 12/31/2022 | N | NEGATIVE | N/A | TT | Naturally present in the environment |

Microbiological Contaminants – Peace River Authority

These contaminants are required to be collected on a monthly basis. Test results are for the period 1/1/2022 – 12/31/2022. Test results for these parameters resulted in no violations.

| Contaminant | Dates of sampling (mo/yr) | Violation Y/N | Total Number of Positive Samples for the Year | MCLG | MCL | Likely source of contamination |
|--|---------------------------|---------------|---|------|-----|--------------------------------|
| <i>E. coli</i> (at the ground water source)*** | 1/1/2022-12/31/2022 | N | 0 | 0 | 0 | Human and animal fecal waste |

Inorganic Contaminants – Peace River Authority

These contaminants are required to be tested annually. Test results are for the period 1/1/2022 – 12/31/2022. Test results for the above contaminants resulted in no violations. Please note that Fluoride is a listed contaminant under the primary Inorganic Contaminant list and the Secondary Drinking Water Standards list. Results for Fluoride is therefore listed in the secondary drinking water standards section and this section of the report.

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL Violation Y/N | Level Detected | MCLG | MCL | Likely Source of Contamination |
|-------------------------------------|---------------------------|-------------------|----------------|------|-----|--|
| Arsenic (ppb) | 1/2022 - 12/2022 | N | 2 | 0 | 10 | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes |
| Barium (ppm) | 1/2022 | N | 0.012 | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Beryllium (ppb) | 1/2022 | N | 2 | 4 | 4 | Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries |
| Fluoride (ppm) | 1/2022 | N | 0.351 | 4 | 4.0 | Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm |
| Nitrate (as Nitrogen) (ppm) | 1/2022 | N | 0.368 | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Nitrite (as Nitrogen) (ppm) | 1/202 | N | 0.046 | 1 | 1 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL Violation Y/N | Level Detected | MCLG | MCL | Likely Source of Contamination |
|-------------------------------------|---------------------------|-------------------|----------------|------|-----|--|
| Selenium (ppb) | 1/2022 | N | 4 | 50 | 50 | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines |
| Sodium (ppm) | 1/2022 | N | 39.6 | N/A | 160 | Saltwater intrusion, leaching from soil |

Stage 1 Disinfectants and Disinfection By-Products – Peace River Authority

As a result of the Disinfection by Product Rule (effective 1/1/2002) the Authority is required to monitor disinfection levels in the distribution system to ensure that the annual average residual of 4.0 mg/l is not exceeded. Test results provided are for the period 1/1/2022 – 12/31/2022 and result in no violations.

| Disinfectant or Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL or MRDL Violation Y/N | Level Detected | Range of Results | MCLG or MRDLG | MCL or MRDL | Likely Source of Contamination |
|---|---------------------------|---------------------------|----------------|------------------|---------------|-------------|---|
| Chlorine and Chloramines (ppm) | 1/1/2022 – 12/31/2022 | N | 3.74 | 3.45-4.04 | MRDLG = 4 | MRDL = 4.0 | Water additive used to control microbes |

Stage 1 Disinfectants and Disinfection By-Products – Peace River Authority

Sub Part H systems require that these contaminants be tested monthly for the raw and finished water as paired samples to determine the treatment facility's percentage of removal and removal ratio of TOC during treatment. Test results are for the period 1/1/2022 – 12/31/2022 on finished and raw untreated water at the Peace River Facility.

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | TT Violation Y/N | Level Detected | Range of Monthly Removal Ratios | MCLG | MCL | Likely Source of Contamination |
|-------------------------------------|---------------------------|------------------|----------------|---------------------------------|------|-----|--------------------------------------|
| Total organic carbon (ppm) | 1/1/2022-12/31/2022 | N | LESS THAN 2.0 | N/A | N/A | TT | Naturally present in the environment |

Stage 2 Disinfectant/Disinfection Byproduct (D/DBP) Parameters – Peace River Authority

| Disinfectant or Contaminant and Unit of Measurement | Dates of sampling (M/yr.) | MCL or MRDL Violation Y/N | Level Detected | Range of Results | MCLG or MRDLG | MCL or MRDL | Likely Source of Contamination |
|---|---------------------------|---------------------------|----------------|------------------|---------------|-------------|---|
| Haloacetic Acids (five) (HAA5) (ppb) | 1/22-12-22 | N | 26.125 | 9.7 – 28.9 | N/A | 60 | By-product of drinking water disinfection |
| THM (total trihalomethanes) (ppb) | 1/22-12/22 | N | 33.5 | 27.7 – 37.4 | N/A | 80 | By-product of drinking water disinfection |

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- A. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife, are listed below.
- B. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- C. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- D. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.
- E. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Lead - If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Peace River Regional is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).